

## What should the supply air temperature be?

Approximately 16 to 20 degrees lower than the return (or rooms) temperature.