

## Should I switch to the new “freon” R410A “Puron”?

If you plan on replacing your system, then yes. R-22 or “freon”; production is slowly being phased out at a rate of 20% a year beginning next year and the cost will rise drastically, also most manufacturers are eliminating stock on R-22 units and will only be selling the R410A units in the next few years.